

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 268846
DIV. 5 WD 51 DES. BASIN MD

APPLICANT

Lot: 10 Block: 2 Filing: 1 Subdiv: COLORADO ANGLERS CLUB

JOHN D DUFOUR
4245 HOYT ST
WHEATRIDGE, CO 80033-2919

APPROVED WELL LOCATION

GRAND COUNTY
SE 1/4 NE 1/4 Section 27
Township 3 N Range 76 W Sixth P.M.

DISTANCES FROM SECTION LINES

2250 Ft. from North Section Line
250 Ft. from East Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

(303) 424-0578

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site of 0.20 acre(s) described as lot 10, block 2, filing 1, Colorado Angler's Club Subdivision, Grand County.
- 4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type, or through the Three Lakes Water and Sanitation District's central waste water disposal system, and the return flow shall be returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: Expired permit no. 255266 was previously issued for this lot *5/9/06*

APPROVED
JSG

State Engineer

DATE ISSUED 05-09-2006

By

EXPIRATION DATE 05-09-2008

Receipt No. 3603242

WELL CONSTRUCTION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

GWS-31
10/94

RECEIVED

JUL 14 2006

WATER RESOURCES
DIVISION

1. WELL PERMIT NUMBER 268846

2. OWNER NAME(S) John Dufaur
Mailing Address 4245 Hoyt St.
City, St. Zip Wheatridge, CO. 80033
Phone (303) 424-0578

3. WELL LOCATION AS DRILLED: SE 1/4 NE 1/4, Sec. 27 Twp. 3 N, Range 76 W 64 pm
DISTANCES FROM SEC. LINES:
2250 ft. from North Sec. line, and 250 ft. from East Sec. line. OR
(north or south) (east or west)
SUBDIVISION: Colo. Anglers Club LOT 10 BLOCK 2 FILING(UNIT) 1
STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION _____ ft. DRILLING METHOD Air Rotary
DATE COMPLETED 6/12/06 TOTAL DEPTH 300 ft. DEPTH COMPLETED 300 ft.

5. GEOLOGIC LOG:

Depth	Description of Material (Type, Size, Color, Water Location)	6. HOLE DIAM. (in.)	From (ft)	To (ft)
0-80'	Sm. Gravel + Sand	9	0	40
		6 5/8	40	80
		5 1/2	80	300
80'-300'	Gray Clay			

7. PLAIN CASING

OD (in)	Kind	Wall Size	From (ft)	To (ft)
6 5/8	Steel	188	0	60
4	PVC	Schd. 200	20	100

PERF. CASING: Screen Slot Size: 1/8"

OD (in)	Kind	Wall Size	From (ft)	To (ft)
6 5/8	Steel	188	60	80
4	PVC	Schd. 200	100	300

8. FILTER PACK:
Material _____
Size _____
Interval _____

9. PACKER PLACEMENT:
Type _____
Depth _____

10. GROUTING RECORD:

Material	Amount	Density	Interval	Placement
CEMENT	9.6 GGT	15	40	Poured

REMARKS: H2O @ 60'

11. DISINFECTION: Type Chlorine Granules Amt. Used 30z.

12. WELL TEST DATA: ☐ Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test.
TESTING METHOD WELL SOUNDER
Static Level 44 ft. Date/Time measured 6/12/06 6:30 pm Production Rate 1.5 gpm.
Pumping level _____ ft. Date/Time measured _____ Test length (hrs.) 4
Remarks _____

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. (Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.)

CONTRACTOR Moody Drilling Inc. Phone (719) 942-4303 Lic. No. 1369
Mailing Address Box 154 Coal Dale Co. 81222 (970) 887-1140

Name/Title (Please type or print) PRES./ Signature _____ Date 07/06/06
MICHAEL C. MOODY OPERATOR

Colorado Division of Water Resources

Colorado's Well Permit Search

THIS PAGE IS NOT THE ACTUAL PERMIT

The information contained on this page is a summary of the permit file and may not reflect all details of the well permit. ([Full Disclaimer](#))

Well Constructed

Receipt: 3603242 **Division:** 5
Permit #: 268846- **Water District:** 51
Well Name / #: **County:** GRAND
Designated Basin: **Management District:**
Case Number:
WDID:

[Help](#) [Last Refresh:](#)

[-] Imaged Documents - Permit File

Document Name	Date Imaged	Annotated
Residential Application	11/28/2007	No
Well Construction	11/28/2007	No
Well Permit	11/28/2007	No

[-] Applicant/Contact

Applicant/Contact Name	Mailing Address	City/State/Zip
DUFOR, JOHN D	4245 HOYT ST	WHEAT RIDGE, CO 80033-2919

[-] Location Information

Approved Well Location:

Q40	Q160	Section	Township	Range	PM	Footage from Section Lines
SE	NE	27	3N	76W	Sixth	2250 N 250 E
Northing (UTM y):		4449514.5		Easting (UTM x):		424800.6
Location Accuracy: Spotted from section lines						

Subdivision Name

COLORADO ANGLERS CLUB NO 1

Filing Block Lot

2 10

Parcel ID: 25-1191-271-14-037

Acres in Tract:

[-] Permit Details

Date Issued: 05/09/2006 **Date Expires:** 05/09/2008

Uses (See [Imaged Documents](#) for more information)

General Use(s): Household use only

Aquifer(s): ALL UNNAMED AQUIFERS

Special Use:

Area which may be irrigated:

Annual volume of appropriation:

Statute:

Cross Reference Permit(s): Permit Number Receipt

Comments: ONLY WELL ON 0.23 ACRE TRACT. TAX #R304169 (LOT 10, BLK 2, PH 1, COLORADO ANGLES CLUB NO. 1). LIMIT USE TO HUO BEING, 1 SFD & NO OUTSIDE USES. PHY ADDRESS: 0042 CR 4037 (AKA COACHMAN DR.). DMW 01/29/15

[-] Construction/Usage Details

Well Construction Date: 06/12/2006

Pump Installation Date:

Well Plugged:

1st Beneficial Use:

Elevation	Depth	Perforated Casing (Top)	Perforated Casing (Bottom)	Static Water Level	Pump Rate
300		60	300		

Driller	Lic #	Name	Address	Phone Number
	1369	MOODY, MICHAEL C.	PO BOX 154 COALDALE, CO 81222	7195308300

[-] Application/Permit History

Well Constructed	06/12/2006
Permit Issued	05/09/2006
Application Received	04/26/2006

Disclaimer

***The information contained on this page is a summary of the permit file and may not reflect all details of the well permit. THIS PAGE IS NOT THE ACTUAL PERMIT.**

This page should not be used as a basis for any legal consideration, to determine the allowed uses of the well, to determine construction information, or to determine the terms and conditions under which the well can operate. The complete well permit file should be viewed to obtain details on the allowed uses and other relevant information. A complete copy of this file is available in the "Imaged Documents" section of this page, and can be viewed by opening all of the documents listed under that section (documents will open as pdf files).

Note that all of the terms and conditions under which a well can operate, particularly for non-exempt wells, may not be specified on the well permit. Wells may also be subject to relevant statutes, rules and decrees. To learn more about well permitting in Colorado, please visit [DWR's Well Permitting Page](#). If you have any questions about this well permit file, please contact the [DWR Ground Water Information Desk](#).

Copyright © 2016 Colorado Division of Water Resources. All rights reserved.

[Home](#) | [Contact Us](#) | [Help](#) | [Water Links](#) | [Colorado.gov](#) | [DNR](#) | [Privacy Policy](#) | [Transparency Online Project \(TOP\)](#)