Form No.
GWS-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 242943 -_____-___
DIV. 5 WD 51 DES. BASIN MD

APPLICANT

LACY FAMILY LLLP
PO BOX 623
GRAND LAKE, CO 80447-

(970) 627-3023

APPROVED WELL LOCATION
GRAND COUNTY
NW 1/4 SE 1/4 Section 12
Township 3 N Range 76 W Sixth P.M.

DISTANCES FROM SECTION LINES
2400 Ft. from South Section Line
1400 Ft. from East Section Line

UTM COORDINATES
Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site of 2.44 acre(s) described as that portion of the NW 1/4 of the SE 1/4, Sec. 12, Twp. 3 N, Rng. 76 W, Sixth P.M., Grand County, more particularly described on the attached exhibit A.
4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
5) The maximum pumping rate of this well shall not exceed 15 GPM.
6) The return flow from the use of this well must be through a central waste water disposal system of the non-evaporative type (Three Lakes Water & Sanitation District), where the water is returned to the same stream system in which the well is located.
7) This well shall be constructed not more than 200 feet from the location specified on this permit.

CE 7 Aug 02

APPROVED
CJE

Hal D. Simpson
State Engineer

By

Receipt No. 9501046A DATE ISSUED AUG 08 2002 EXPIRATION DATE AUG 08 2004